

# IN-LINE PASSIVE INFRARED OCCUPANCY SENSOR

ORDERING RP-LBI-PIR-A, IN ADDITION TO THE LBI PART NUMBER, UPGRADES THE FIXTURE W/ A SIMPLE CONTROL IN-LINE PASSIVE INFRARED OCCUPANCY SENSOR.



# ATTRIBUTES

DETECTION TECHNOLOGY	PASSIVE INFRARED (PIR)
DETECTION TYPE	OCCUPANCY
SENSOR POWER	12VDC
GROUPABLE	NO
NETWORK LIGHTING CONTROL	NO
COMISSIONING METHOD	IR REMOTE
REMOTE	IR11
DAYLIGHT HARVESTING	YES
HI OR LOW TRIM	NO
BI-LEVEL DIMMING	YES
NETWORK TECHNOLOGY	NONE
INSTALLATION TYPE	INTERNAL
DLC LISTED	YES
CONTROL CAPACITY	15 BARS


#### **IR11 REMOTE**




FOR MORE INFORMATION ON THE IR11 REMOTE SCAN BELOW



## **DETECTION PATTERN / RP-LBI-PIR-A**





## **DAYLIGHT HARVESTING / RP-LBI-PIR-A**

Sensor detects the difference between natural light and artificial light (lamp) from behind the diffuser, switch on automatically (even w/o movements) when the ambient light is below the target value, and switch off automatically whenever the artificial light is not required (ambient light is bright enough).

**NOTE** LUX-OFF SAMPLING TIME - 30S. LUX-ON SAMPLING TIME - 10S. LUX-ON FUNCTION WILL ONLY OPPERATE WITHOUT MOTION WHEN STANDBY IS SET TO  $+\infty$ .

